



Office of the District Fire Officer,
Karnataka State Fire and Emergency services,
Davanagere Fire station premises,
Davanagere Dist-577003.



C.No:20/RCC/SCI/117/DFO/DVG/2025

Date:21/11/2025

To,

The Principal

"Colors School"

(Dise code no- 29140411007)

Mahajenahalli Village, Shivamogga Road

Harihara Taluk ,Davanagere District -577601.

Sir,

Sub: Renewal of **Fire safety Compliance Certificate** to "**Colors School**" situated at Mahajenahalli Village, Shivamogga Road Harihara Taluk ,Davanagere District - 577601.

- Ref: 1) The Chief Fire Officer, Office Fire Safety Recommendation
C.No:863/CFO/BWZ/2020 Date:24/12/2020
2) The Chief Fire Officer, Office Compliance Certificate.
C.No:863/FSR/CFO/BWZ/2021 Date:24/07/2021
3) Your Letter Dated: 07/11/2025


>>>><<<<

With reference to subject cited above, Fire Safety Recommendation letter was issued vide reference (1) "**Colors School**" situated at Mahajenahalli Village, Shivamogga Road Harihara Taluk ,Davanagere District -577601. with a condition to fulfill the Recommendations and compliance the same. **Compliance Certificate** Was Issued to The building Vide ref. (2)

With reference cited (3) above, The Principal , "**Colors School**" situated at Mahajenahalli Village, Shivamogga Road Harihara Taluk ,Davanagere District -577601. had requested for Renewal of the **fire safety Compliance Certificate** from our department. In this regard the building was inspected by me on 15/11/2025 to issue **Renewal of compliance Certificate**.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "**Renewal of Fire Safety Compliance Certificate**" to , "**Colors School**" situated at Mahajenahalli Village, Shivamogga Road Harihara Taluk ,Davanagere District -577601. subject to proper maintenance of fire fighting installations in good working condition and impart 40% of employees should be trained in basic fire fighting at R.A. Mundkur Fire and Emergency Services Academy, Bannerughatta road, Bangalore or the Regional fire officer, davanager range, davanagere fire station premises, davanagere within 90 days from the date of issue of this report.

This fire safety compliance certificate is valid till dated 20/11/2027 and it is renewable without fail



Ashwini

Principal

COLORS SCHOOL

Shimoga Road,
HARIHARA - 577601.

Yours faithfully

[Signature]
District Fire Officer
Karnataka Fire & Emergency Service
Davanagere District

For K.G.N.S. Educational Trust (R)

[Signature]
Secretary